

2024 Water Quality Report for Village of Fowler

Water Supply Serial Number: 2390

This report covers the drinking water quality for the Village of Fowler for the 2024 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2024. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (USEPA) and state standards.

Your water comes from 2 groundwater wells, located at 1915 N. Wright Rd. Each well is over 160 feet deep. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is low.

There are no significant sources of contamination in our water supply. We are making every effort to protect our sources by participating in the Well head protection program. The Village urges all of its citizens to recognize the water quality basics of source protection, conservation, and personal involvement, and to recognize the value, importance, and fragility of our water source.

If you would like to know more about this report, please contact: Vern Feldpausch at 989 593-2768 or you can e-mail me at Fowlerdpw@fowlermi.com.

Contaminants and their presence in water:

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **USEPA's Safe Drinking Water Hotline (800-426-4791)**.

Vulnerability of sub-populations:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the **Safe Drinking Water Hotline (800-426-4791)**.

Sources of drinking water:


The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals,

which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

To ensure that tap water is safe to drink, the USEPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.



Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2024 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2024. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.
- **N/A:** Not applicable
- **ND:** not detectable at testing limit
- **ppm:** parts per million or milligrams per liter
- **ppb:** parts per billion or micrograms per liter
- **pCi/l:** picocuries per liter (a measure of radioactivity)
- **Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

¹Monitoring Data for Regulated Contaminants

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Arsenic (ppb)	10	0	N/D	N/A	2024	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Fluoride (ppm)	4	4	.70	N/A	2024	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A	N/A	48	N/A	2024	No	Typical source is erosion of natural deposits
Chlorine ¹ (ppm)	4	4	1.20	.9 -1.6	2024	No	Water additive used to control microbes
Alpha emitters (pCi/L)	15	0	1.9	N/A	2024	No	Erosion of natural deposits
Combined radium (pCi/L)	5	0	0	N/A	2024	No	Erosion of natural deposits

Inorganic Contaminant Subject to ALs	AL	MCLG	Your Water ²	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant
Lead (ppb)	15	0	1	0 -2	2024	0	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits

¹ The chlorine “Level Detected” was calculated using a running annual average.

² Ninety (90) percent of the samples collected were at or below the level reported for our water.

Copper (ppm)	1.3	1.3	.20	0 -3	2024	0	Corrosion of household plumbing systems; Erosion of natural deposits
--------------	-----	-----	-----	------	------	---	---

Additional Monitoring.

Unregulated contaminants are those for which the U.S. EPA has not established drinking water standards. Monitoring helps the U.S. EPA determine where certain contaminants occur and whether regulations of those contaminants is needed.

Unregulated Contaminant	Level Detected(ppm)	Year Sampled	Comments
Lithium	.021(ppm)	2025	Results are available upon request

Information about lead: Lead can cause serious health effects in people of all ages, especially pregnant women, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. The Village of Fowler is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certified to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement services line, you may need to flush your your pipes for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water and wish to have your water tested, contact the Village of Fowler D.P.W. at 989 593-2768 for available resources. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Our water supply has no lead service lines out of a total of 538 service lines.

We are required by the State of Michigan and the U.S. EPA to sample our water for specific contaminants on a regular basis, and to report those results. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. Our water is safe and your water is meeting all requirements that govern the water system.

We are committed to providing you safe, reliable, and healthy water. We will update this report annually and will keep you informed of any problems that may occur throughout the year as they

happen. Copies of this report are available at the Village of Fowler office at 225 N. Main St. or you can review this report on line at Fowlervillage@fowlermi.com,

We invite public participation in decisions that affect drinking water quality. Please contact the D.P.W. during regular office hours. Or you can attend a Fowler Village meeting held on the second Tuesday of every month at 7:00 p.m. For more information about your water or the contents of this report, contact Vern Feldpausch at 989 593-2768. For more information about safe drinking water, visit the USEPA at <http://www.epa.gov/safewater>.